



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7167-2142:0508
<b>CATEGORY:</b>	7167 - CONTROL UNIT (HOUSEHOLD)
<b>LISTEE:</b>	QOLSYS 1919 S. Bascom Ave, Ste. 600, Campbell, CA, 95008 Contact: Nita, Dan 4163571409 Email: dan.nita@jci.com
<b>DESIGN:</b>	Qolsys Model IQPanel5, IQ5Hub, and IQ5NS Household Fire Alarm Control Units. Product utilizes RF technologies at a frequency of 912-919MHz, 319.5MHz, 345MHz, 433.92MHz, or 2.4GHz to receive status, alarm, and restoral signals from separately Listed compatible initiating and notification devices. Minimum system configuration shall consist of a separately Listed compatible smoke detectors (QS5130-840, PGP9976 or CMB-937), compatible Listed central station receiver, and the cellular communication shall be enabled. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	Primary: SW-120100A power supply. Input: 100-240Vac, 50/60Hz, 0.68 A, Output: 12.0Vdc, 1000mA  Secondary Battery: IAN034NA or VT27: 3.7 V, 3000 mAh.
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, date of manufacture, and UL label.
<b>APPROVAL:</b>	Listed as a household fire alarm control unit for use with the below separately listed compatible initiating devices. Models comply with the applicable requirements in UL 985, 6th Edition. Refer to listee's Installation Instruction Manual for details.  Compatible Wireless Initiating Devices: QOLSYS - Model QS5110-840 (CSFM Listing No. 7272-2142:0502) QOLSYS - Model QS5210-840 (CSFM Listing No. 5278-2142:0503) QOLSYS - Model QS5130-840 (CSFM Listing No. 7272-2142:0507) Tyco Safety Products Canada Ltd. - Model PG9936 (CSFM Listing No. 7272-1273:0508) Tyco Safety Products Canada Ltd. - Model PGP9976 (CSFM Listing No. 7272-1273:0525)



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

	<p>Tyco Safety Products Canada Ltd. - Model PGP9979 (CSFM Listing No. 7270-1273:0526)</p> <p>Tyco Safety Products Canada Ltd. - Model PG9936 (CSFM Listing No. 7272-1273:0508)</p> <p>Tyco Safety Products Canada Ltd. - Model PG9933 (CSFM Listing No. 5278-1273:0509)</p> <p>Tyco Safety Products Canada Ltd. - Model WS4936 (CSFM Listing No. 7272-1273:0503)</p> <p>Tyco Safety Products Canada Ltd. - Model WS4933 (CSFM Listing No. 5278-1273:0510)</p> <p>Resideo LLC - Model 5800COMBO (CSFM Listing No. 7275-1645:0502)</p> <p>Resideo LLC - Model 5800CO (CSFM Listing No. 5278-1645:0515)</p> <p>System Sensor - Model 5806W3 and 5808W3 (CSFM Listing No. 7272-1653:0193)</p> <p>Misc. Accessories:</p> <p>Tyco Safety Products Canada Ltd. - Model PG9920 (CSFM Listing No. 7300-1273:0520)</p> <p>Tyco Safety Products Canada Ltd. - Model PG9WLSHW8 (CSFM Listing No. 7300-1273:0512)</p> <p>Tyco Safety Products Canada Ltd. - Model WS4920 (CSFM Listing No. 7300-1273:0142)</p> <p>Tyco Safety Products Canada Ltd. - Model SG-System 5 (CSFM Listing No. 7300-1273:0157)</p> <p>Tyco Safety Products Canada Ltd. - Model PG9901 (CSFM Listing No. 7135-1273:0148)</p> <p>Tyco Safety Products Canada Ltd. - Model PG9911 (CSFM Listing No. 7135-1273:0149)</p> <p>Tyco Safety Products Canada Ltd. - Model PG9945 (CSFM Listing No. 7300-1273:0513)</p> <p>Tyco Safety Products Canada Ltd. - Model PG9309 (CSFM Listing No. 7300-1273:0515)</p> <p>Resideo LLC - Model 5815 (CSFM Listing No. 7300-1645:0112)</p>
<p><b>NOTES:</b></p>	<p>1. For household system, Fire Alarm Verification Feature (delay of fire alarm signal) shall not be used in California.</p> <p>2. Burglary and other non-fire functions were not examined.</p>

03-12-26 MH



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 03/13/2026**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division